

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 20391
Date: 4/20/16

Detailed Product Description:

Manufacturer: PORCELANOSA USA

Manufacturer Address: 8700 NW 13 TERRACE – MIAMI, FL 33172


Model Name: PORCELAIN PANEL, BY PORCELANOSA GRUPO - RAINSCREEN VENTILATED FACADE SYSTEM

Maximum Tile Width: 47 1/4"

Maximum Tile Height: 23 7/16"

Maximum Load: +62PSF, -62 PSF (Small Missile Impact)

Installation Drawings # 16-03

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
Comparative analysis used <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E330 & TAS 202	Uniform Static Air Press.	Architectural Testing	01/20/2016 01/29/2016	E5710.01-109-18 E5708.01-109-18	Joseph A. Reed, PE Joseph A. Reed, PE
Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.3 (TAS 201 & 203)	Small Missile Impact & Cyclic	Architectural Testing	01/20/2016 01/29/2016	E5710.01-109-18 E5708.01-109-18	Joseph A. Reed, PE Joseph A. Reed, PE
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2014 Florida Building Code.					
Evaluation Report Engineer:					
Javad Ahmad Al-Farooq Corporation	PE # 70592 EB # 3538				

Sealed 4-20-16